

PROVINCE OF BRITISH COLUMBIA
REGULATION OF THE ATTORNEY GENERAL AND
MINISTER RESPONSIBLE FOR HOUSING

Safety Standards Act

Ministerial Order No. M241

I, Murray Rankin, Q.C., Attorney General and Minister Responsible for Housing, order that, effective October 1, 2022, the Electrical Safety Regulation, B.C. Reg. 100/2004, is amended as set out in the attached Appendix.

Aug 11, 2022

Date



Attorney General and Minister Responsible for Housing

(This part is for administrative purposes only and is not part of the Order.)

Authority under which Order is made:

Act and section: *Safety Standards Act*, S.B.C. 2003, c. 39, ss. 8 and 88

Other: M58/2004

R20605718

APPENDIX

- 1** *Section 7 (4) of the Electrical Safety Regulation, B.C. Reg. 100/2004, is amended by striking out “750 volts” and substituting “1 000 volts”.*
- 2** *Section 8 (1) is amended*
 - (a) by striking out “and” at the end of paragraph (b),*
 - (b) by adding “and” at the end of paragraph (c), and*
 - (c) by adding the following paragraph:*
 - (d) have work experience acceptable to a provincial safety manager.*
- 3** *Section 9 (1) (b) is amended by striking out “Applied Science Technologists and Technicians Act” and substituting “Professional Governance Act”.*
- 4** *Section 20 is repealed and the following substituted:*

Canadian Electrical Code adopted as B.C. Electrical Code

- 20** The Canadian Electrical Code, Part I, Twenty-fifth Edition, Safety Standard for Electrical Installations, Canadian Standards Association Standard C22.1:21, amended as set out in the Schedule to this regulation and including any errata, is adopted by reference as the B.C. Electrical Code.
- 5** *Section 1 of the Schedule is amended by striking out “the Canadian Electrical Code, Part I, Twenty-fourth Edition, Safety Standard for Electrical Installations, Canadian Standards Association Standard C22.1-18” and substituting “the Canadian Electrical Code, Part I, Twenty-fifth Edition, Safety Standard for Electrical Installations, Canadian Standards Association Standard C22.1:21”.*